

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:58 pm

PWS ID: UTAH26009 **Name:** WALLSBURG TOWN WATER SYSTEM

Legal Contact: WALLSBURG TOWN WATER SYS **Rating:** Approved
RICK C SABEY **Rating Date:** 05/19/2006

Address: PO BOX 203 **Activity Status:** Active
WALLSBURG, UT 84082

Phone Number: 435-654-4934

City Served (Area):

County: WASATCH COUNTY

System Type: Community **Last Inv Update:** 01/05/2011 **Avg Daily Prod:**

Activity Status Cd: Active **Last Snty Srv Dt:** 06/09/2008 **Total Dsgn Cap:**

Population: 400 **Surveyor:** DWIGHT HILL **Total Emerg Cap:**

Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	SABEY, RICK C		435-657-1872		rcsabey@hotmail.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	101
Commercial	Unknown	0	5
			106 Total Svc Connections

Storage

Total Storage: 225,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	UPPER TANK	Ground	100,000 GAL	Concrete		A	NO
ST002	LOWER TANK	Ground	125,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	WARM SPRING CHLORINATOR		I	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WARM SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	TOWN WELL	Active	WL	8	327 GPM	327 GPM	Yes	GW	Seasonal		

*Reports measured flow for wells, approved design capacity for all other sources.